

OFFICE USE ONLY
 Log No. 75382
 Permit No. 212
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18569

1. OWNER WOOD BINE SOUTHWEST CORP ADDRESS AT WELL LOCATION 101 MONTELAGO BLVD
 MAILING ADDRESS 101 MONTELAGO BLVD HENDERSON, NV 89011

2. LOCATION S $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 22 T. 21 N/S R. 63 E. CLARK County
 PERMIT NO. DW1097 160-22-510-005
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other Dewater

4. PROPOSED USE dewater WELL TYPE
 Domestic Irrigation Test Cable Rotary RVC
 Municipal/Industrial Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Dewater wells 1-4				
Aluvium		0	9	
Clay & Aluvium		10	20	
Sand clay mix		20	27	
<u>well 04</u>				

8. WELL CONSTRUCTION
 Depth Drilled 27' Feet Depth Cased 27' Feet

HOLE DIAMETER (BIT SIZE)
 From 24" Inches 0 Feet 27 Feet
 To _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8"</u>		<u>sch40</u>	<u>0</u>	<u>27</u>

Perforations:
 Type perforation Machine
 Size perforation 1/4"x2 1/2"x3 rows

From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 0 feet to 27' feet

9. WATER LEVEL
 Static water level: 9' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
ALLEN DRILLING INC.
 Name _____
 Address 4847 S. VALLEY VIEW
LAS VEGAS, NV 89103
 Nevada contractor's license number 18916
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1301 ABDS 2043
 Signed [Signature]
 Date 3-18-99

Date started 3-5 1999
 Date completed 3-5 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

