WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75388
Permit No.
Basin 42

NOTICE OF INTENT NO. 404[illegible]

1. OWNER FEARLESS FERRIS STINKER STATIONS
MAILING ADDRESS P.O. BOX 7627
BOISE, ID 83707

ADDRESS AT WELL LOCATION 1010 6TH STREET, WELLS, NV

2. LOCATION NW 1/4 SE 1/4 Sec. 10 T 37N N/S R 62E E ELKO County
PERMIT NO. HOLE #5 (Issued by Water Resources) | 002-760-001 (Parcel No.) | TRACT OF LAND (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
COARSE GRAVEL & SAND		0	10	10
FLUSH MOUNT MONUMENT CEMENTED AT SURFACE				

RECEIVED 99 MAY 7 AM 11:56 ENGINEERING DIVISION

Date started 3/23/99 , 19__
Date completed 3/23/99 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA	NA	NA

8. **WELL CONSTRUCTION**
Depth Drilled 10 Feet Depth Cased 10 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	10	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.5	PVC	SCH 40	0	10

Perforations:
Type perforation MACHINE SLOT
Size perforation .020
From 5 feet to 10 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 3'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 3 feet to 10 feet

9. **WATER LEVEL**
Static water level N/A feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1395
Signed George M Aldhiem (By driller performing actual drilling on-site or contractor)
Date 3/24/99

USE ADDITIONAL SHEETS IF NECESSARY