WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75395
Permit No.
Basin 218

NOTICE OF INTENT NO. 18601

1. OWNER: Glendale Service, INC.
MAILING ADDRESS: 2300 E Glendale Blvd Glendale, Nevada
ADDRESS AT WELL LOCATION: SAME

2. LOCATION: ¼ NE ¼ Sec. 2 T. 15 S R. 66 E. Clark County
PERMIT NO. (Issued by Water Resources) 000-170-014/010 (Parcel No.) Subdivision Name

3. WORK PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other TSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Red/Brown silts & fine sands, some medium sands, trace coarse sands, trace fine gravels		0	3	
Little clays		3	4.5	
Brown silts and fine sands, little clays		4.5	6.0	
Brown clays & silts, some fine sand, little medium sands, trace coarse sand		6.0	9.5	
Silts, clays and fine sands, little coarse sands, trace fine gravels		9.5	12	
fine coarse gravels (4") little silts and clay		12	17	
Black coarse sand, little fine gravels, little medium sands, trace silts and fine sands		17	25	

Date started 4.15, 1999
Date completed 4.13, 1999

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	5 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4			0	5

Perforations:
Type perforation: Sch 40 PVC
Size perforation: .020
From 5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 3 feet to 25 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) THE VERDE COMPANIES, INC.
Address (Contractor) 301 WEST DEER VALLEY #7
PHOENIX, ARIZONA 85027
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1207071
Signed (By driller performing actual drilling on site or contractor)
Date 5/20/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627