

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 75431
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **39798**

1. OWNER **Ken Berry** ADDRESS AT WELL LOCATION **Bronze Hill Rd Reno, NV**
 MAILING ADDRESS **Bronze Hill Rd** **89506**
Reno, NV 89506 *2105 Antelope Valley Road*

2. LOCATION **SE** 1/4 **SE** 1/4 Sec. **14** T **22** N/S R **19** E **Washoe** County
 PERMIT NO. _____ Parcel No. **079-480-75-481-03** Subdivision Name **Red Rock Estates # 2695 part 2**

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock _____
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown sandy D.G		0	7	
Brown sandy clay		7	22	15
Multi colored course sand		22	50	28
Weathered granite hard		50	63	13
Salt & pepper granite hard			100	37
Salt & pepper granite fractured		100	200	100
T.D. 200'				

8. WELL CONSTRUCTION

Depth Drilled **200** Feet Depth Cased **200** Feet

HOLE DIAMETER (BIT SIZE)

	From	To		
10 5/8	Inches	0	Feet	50
8 1/2	Inches	50	Feet	200
	Inches		Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	17.0	.225	+ 1 1/2	200

Perforations:
 Type perforation **factory sawed**
 Size perforation **3/32X3**

From	feet to	feet
	160	180
From	feet to	feet

Surface Seal: Yes No Seal Type: _____
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **200** feet to **50** feet

9. WATER LEVEL
 Static water level **80** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cold** °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **A.S.A.P. Pump & Well Service Inc.** Contractor
 Address **P.O. Box 60130** Contractor
Reno, NV 89506
 Nevada contractor's license number issued by the State Contractor's Board **35387-A**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2066**
 Signed *Sony Welch*
 By driller performing actual drilling on-site or contractor
 Date **5/13/99**

Date started **5/6/99**, 19____
 Date completed **5/9/99**, 19____

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2 hours