WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75433
Permit No.
Basin 101

NOTICE OF INTENT NO. 41605

1. OWNER Frank Woolsey
MAILING ADDRESS 2161 W Williams #280
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4235 Raven Drive,
Fallon, NV 89406

2. LOCATION NE 1/4 NE 1/4 Sec. 28 T 19N N/S R 28E E Churchill County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	8	8
Brown Clay		8	17	9
Brown Sand		17	26	9
Brown Clay		26	36	10
Brown Sand		36	38	2
Gray Clay		38	42	4
Gray Sand		42	54	12
Gray Clay		54	58	4
Gray Grayish Brown		58		
Clay			62	4
Brown Sand		62	69	7

Date started 4/13/99, 19__
Date completed 4/13/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1hr

8. WELL CONSTRUCTION
Depth Drilled 69 Feet Depth Cased 69 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	69	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	.188	0	10
6 PVC	3.92	.258	10	69

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 66 feet to 69 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60 feet to 69 feet

9. WATER LEVEL
Static water level 11.6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling,Inc. (Contractor)
Address P.O. Box 1264 (Contractor)
Fallon, Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1753
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 4/14/99

USE ADDITIONAL SHEETS IF NECESSARY