

OFFICE USE ONLY
 Log No. 75479
 Permit No. _____
 Basin. 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT 4570

1. OWNER Contra ADDRESS AT WELL LOCATION On #101
 MAILING ADDRESS UNV W. 86 ALOHA
 2. LOCATION N 2 NE 1/4 Sec. 17 T 21 S R 69 E Clark County
 PERMIT NO. DO III 161-17-891-036 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RYC
 Air Other bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy clay</u>		<u>0</u>	<u>17</u>	
<u>Med Sand & GRAVEL</u>		<u>17</u>	<u>20</u>	
<u>Sand clay w/ GRAVEL</u>		<u>20</u>	<u>27</u>	
<u>Sand clay</u>		<u>27</u>	<u>50</u>	

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 50 Feet
 HOLE DIAMETER (BIT SIZE)
24 Inches From 0 Feet To 50 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>PVC</u>	<u>5/8</u>	<u>0</u>	<u>50</u>

Perforations:
 Type perforation slot
 Size perforation 0.52
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 10 feet to 50 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 50 feet

9. WATER LEVEL
 Static water level 10 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 71 °F Quality _____

Date started 5-7-79
 Date completed 5-7-79

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDX Contractor
 Address 536 E Maryland Contractor
Orlando
 Nevada contractor's license number 3246 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1968
 Signed De Lane
 By driller performing actual drilling on site or contractor
 Date 5-7-79