

OFFICE USE ONLY  
 Log No. 75488  
 Permit No. \_\_\_\_\_  
 Basin. 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16570

1. OWNER Carth ADDRESS AT WELL LOCATION On #15 I  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION N - 1/2 NE 1/4 Sec. 17 T. 21 S. R. 2 E Clark County  
 PERMIT NO. DW 1111 Issued by Water Resources Parcel No. 16-17-801-036 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay		0	17	
med sand				
gravel		17	19	
Sandy clay		19	32	
Silty sand		32	35	
clay		35	40	

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 40 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 24 Inches To 40 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>100</u>	<u>40</u>	<u>0</u>	<u>40</u>

Perforations:  
 Type perforation slt  
 Size perforation .032  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 10 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 0 feet to 40 feet

9. WATER LEVEL  
 Static water level 9 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 71 °F Quality \_\_\_\_\_

Date started 5-12 1999  
 Date completed 5-12 1999

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GDK Contractor  
 Address 536 E. 1st St. Las Vegas Contractor  
 Nevada contractor's license number 3246 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1968  
 Signed \_\_\_\_\_ By driller performing actual drilling on site or contractor  
 Date 6-2-99