

OFFICE USE ONLY
 Log No. **75493**
 Permit No. _____
 Basin. **212**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16962

1. OWNER Clifford & Paulette Taylor ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4921 Elmhurst Lane Vacant 5090 N TEE PEE LN
Las Vegas, Nev. 89108
 2. LOCATION NE 1/4 SE 1/4 Sec. 31 T.19S R.60 E. Clark County _____
 PERMIT NO. 125-31-702-002 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____


6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	130	
Cemented Gravel		130	385	
Gravel & Water	xx	385	400	
Cemented Gravel		400	460	
Gravel & Water	xx	460	480	
Cemented Gravel		480	560	
Gravel & Water	xx	560	585	

8. WELL CONSTRUCTION
 Depth Drilled 585 Feet Depth Cased 585 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 55 Feet
10 5/8 Inches 55 Feet 585 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	585

Perforations:
 Type perforation Factory
 Size perforation 3/16 x 8 row
 From 545 feet to 565 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 55 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet



Date started 5/10/99 19_____
 Date completed 5/14/99 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 345 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 5360 Bonita Vista Contractor
Las Vegas, Nev. 89129
 Nevada contractor's license number 10062 issued by the State Contractor's Board
 Nevada driller's license number issued by the 552 Division of Water Resources, the on-site driller
 Signed VH Dimick By driller performing actual drilling on site or contractor
 Date 5-15-99

