WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75495
Permit No. 53210
Basin 212

NOTICE OF INTENT NO. 16593

1. OWNER Ronald & Debra Erskine
MAILING ADDRESS 3701 East Waikiki Las Vegas Nev. 89104
ADDRESS AT WELL LOCATION 1604 Blue Diamond

2. LOCATION SE ¼ NW ¼ Sec. 15 T. 22 N/S R. 59 E. Clark County
PERMIT NO. 53210 (Issued by Water Resources) 177-15-202-003 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic Comm ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravel Boulders		0	150	
Red Sand Stone		150	160	
Yellow Sand Stone		160	175	
Brown Shale	3	175	200	
Lime Stone		200	225	
Sand Gravel Boulder		225	325	
Brown Shale		325	350	
Lime Stone	40	350	400	

JUN 9 1999

Date started 5-3, 1999
Date completed 5-18, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1/2 hour

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10"	0	400

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		PVC Sch 40	+2	400
8 5/8		188	+2	5

Perforations:
Type perforation Saw
Size perforation 1/8
From 340 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 58 feet to 400 feet

9. WATER LEVEL
Static water level 150 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature 60.1 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Redding Drilling (Contractor)
Address 5170 Haven (Contractor)
Lv NV 89123
Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1798
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5-21-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627