WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75504
Permit No.
Basin 162

NOTICE OF INTENT NO. 18825

1. OWNER Frank Montoya
MAILING ADDRESS 791 W. Maria
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
791 W. Maria
Pahrump, NV 89048

2. LOCATION NW ¼ SW ¼ Sec. 9 T. 20s N/S R. 53 E. Nye County
PERMIT NO. 35-174-09 (Issued by Water Resources) | 35-174-09 (Parcel No.) | Cal Vegas Ranchos Unit D, Lot 35 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Grey clay		4	12	8
Soft brown clay		12	38	26
Grey clay		38	78	40
Brown clay	x	78	95	17
Hard spot		95	105	10
Brown clay	x	105	140	35

DCNR/DWR Received APR 14 1999 LAS VEGAS OFFICE

Date started 3-22-99, 19
Date completed 3-23-99, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	-0-	15 min

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	140 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17#	.188	0	140

Perforations:
Type perforation Torch cut
Size perforation 3/4" wide x 8" long
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 44 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg Well Drilling (Contractor)
Address 1060 W. Basin Rd. (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg by CSH (By driller performing actual drilling on site or contractor)
Date 4-2-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627