WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 15564
Permit No.
Basin 212

18562
NOTICE OF INTENT NO.

1. OWNER CLARK CO. SANITATION DISTRICT
MAILING ADDRESS 5825 S. POLARIS AVE.
LAS VEGAS, NV 89193

ADDRESS AT WELL LOCATION CCSD DAFT FACILITY
5825 SOUTH POLARIS AVE.
LAS VEGAS, NV 89193

2. LOCATION ¼ NW ¼ Sec. 22 T. 21 N/S R. 62 E. CLARK County
PERMIT NO. Issued by Water Resources | Parcel No. 161-22-101-001 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Dewater

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Dewater

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well #10 & 11 Dewater wells.				
Sandy aluvium		0	10	
Clay sand mix, water		10	15	
Loose silts, sand mesh clay		15	38	
Grey clay, some pea gravel		38	40	
well 10				

Received
LVB 1999
LAS VEGAS OFFICE

Date started 3-23, 1999
Date completed 3-23, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40' Feet. Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
24" Inches	0 Feet	40 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.71	.250	0	40

Perforations:
Type perforation Machine
Size perforation 3/16x2 1/2x14 around
From 0 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 40' feet

9. WATER LEVEL
Static water level 10' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN DRILLING INC.
Company
Address 4847 S. VALLEY VIEW
Contractor
LAS VEGAS, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 18916
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ~~1301~~ ABDS 2043

Signed Jim Geller
By driller performing actual drilling on site or contractor
Date 4-1-99

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627