WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. [redacted] 75640
Permit No. 64247
Basin 164A
In Book

NOTICE OF INTENT NO. 31822

1. OWNER Primadonna Corp.
MAILING ADDRESS P.O. Box 19129
Jean, NV 89019-9119

ADDRESS AT WELL LOCATION Primm, NV
WP1-XW

2. LOCATION SE ¼ NW ¼ Sec. 8 T. 27 S/S R. 59 E. MDBM Clark County
PERMIT NO. 64247/W-2080 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other RCR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gray Dolomite/L.S.	No	0	160	160
Gray Dolomite/L.S.	yes	160	215	55
Brown-Gray Shale	yes	215	320	105
Brown Sandstone	No	320	325	5
Brown-Gray L.S. + Shale	No	325	345	20
Brown Shale	No	345	360	15
Gray-Brown Shale	yes	360	535	175
Brown-Gray Shale + L.S.	yes	535	585	50
Gray Shale	No	585	600	15
Gray Tan Shale + S.S.	No	600	605	5
Gray Brown Sandstone	No	605	615	10
Gray Brown SS w/ gray shale	No	615	625	10
Gray Sandstone	No	625	655	30
Brown Sandstone	No	655	680	25
White Sandstone	yes	680	700	20
White-gray sandstone	yes	700	755	55
red Sandstone	No	755	775	20
Gray-red sandstone	No	775	870	95
Gray Sandstone	yes	870	879	9
metamorphic Basement rock	yes	879	935	56

RECEIVED SEP 18 AM 11:26 ENGINEERING OFFICE

CONFIDENTIAL Received SEP 11 1998 LAS VEGAS OFFICE

Date started August 4, 1998
Date completed August 10, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
airlift	145	N/A	N/A

8. WELL CONSTRUCTION
Depth Drilled 935' Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	935 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
none				

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal Hole abandoned
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No abandoned according to N.R.S.
From feet to feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 79 °F Quality poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gustin Corp. (Contractor)
Address PO Box 894 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 22193
Nevada driller's license number issued by the Division of Water Resources, the on-site driller [redacted] 1821
Signed [redacted] 1821 (By driller performing actual drilling on site or contractor)
Date 9-3-98

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627