WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75644
Permit No.
Basin 162

NOTICE OF INTENT NO. 19041

1. OWNER Castro
MAILING ADDRESS 520 Amarillo Ave
Pahrump, Nevada 89048
ADDRESS AT WELL LOCATION 520 Amarillo Ave

2. LOCATION NW ¼ SE ¼ Sec. 28 T. 20 S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 40-271-10 (Parcel No.) Caluada Valley Unit 5 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0'	5'	5'
White clay		5'	20'	15'
caliche		20'	30'	10'
white clay		30'	45'	15'
caliche		45'	50'	5'
brown clay		50'	70'	20'
green clay		70'	80'	10'
caliche		80'	90'	10'
brown clay		90'	105'	15'
caliche		105'	110'	5'
brown clay		110'	140'	30'

RECEIVED 99 MAY 24 AM 11:48 STATE ENGINEER'S OFFICE

Date started April 26, 1999
Date completed April 29, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0	140'

Perforations:
Type perforation Saw cut
Size perforation 1/8" X 3"
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ron Naillon Drilling (Contractor)
Address P.O. Box 265 (Contractor)
Pahrump Nevada
Nevada contractor's license number issued by the State Contractor's Board 0035704
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest LaRue (By driller performing actual drilling on site or contractor)
Date May 7, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627