MONITORING

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75662
Permit No.
Basin 212

NOTICE OF INTENT NO. 182(30)53

1. OWNER Southern Nevada Water Authority
MAILING ADDRESS 1900 E. Flamingo Rd. Ste. 170 Las Vegas, NV 89119
ADDRESS AT WELL LOCATION Vegas Valley Rd & Sloan Wash

2. LOCATION ¼ SE ¼ Sec. 10 T. 21S N/S R. 62 E. Clark County
PERMIT NO. [illegible] Issued by Water Resources | 161-10-802-002 Parcel No. | Granite Const. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Monitoring

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. #1 48+00E LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
1 0-Compacted Red clay		0	5	5
2 Clay with Small Amount of Gravel		5	10	5
3 Gravel-Small Amount of Clay First Water	11	10	15	5
4 Sand & Gravel Water Bearing Zone	11	15	20	5

DCNR/DWR Received APR 26 1999 LAS VEGAS OFFICE

Date started 6-30, 1998
Date completed 6-30, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
None		Monitor	Checked Static

8. WELL CONSTRUCTION
Depth Drilled 20' Feet Depth Cased 20' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	20 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	Sch-40	0	20

Perforations:
Type perforation Factory Slots
Size perforation .020
From 10 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 8'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 20 feet to 10 feet

9. WATER LEVEL
Static water level 11' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Foothill Eng. & Dewatering Contractor
Address 905 E. Third St. Coronado 71912 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0035906
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1645-T1
Signed [signature] By driller performing actual drilling on site or contractor
Date 7-2-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627