WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

75673 OFFICE USE ONLY (P.2)
Log No. ~~24648~~
Permit No.
Basin 85

WELL DRILLERS REPORT

Spring Creek Please complete this form in its entirety

1. OWNER Pyramid Ranch Homes ADDRESS Pyramid Highway No address given

2. LOCATION SE ¼ NE ¼ Sec. 21 T. 20 N/S R. 20 E. Washoe County
PERMIT NO. 43629

3. TYPE OF WORK
Test ~~New~~ Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay		0	4	
Hard fractured				
Volcanic rock		4	65	61
Hard packed				
Sandy clay		65	90	25
Volcanic rock	X	90	115	25
Sandy clay	X	115	195	80
Hard fractured				
Volcanic rock	X	195	260	65
Hard clay		260	295	35
Volcanic rock	X	295	335	40
granite type rock	X	335	402	67
sandstone type rock		402	579	177
soft sandstone		579	660	81
factured Volcanic rock	X	660	678	15
soft grey rock		678	697	19
Hard black Volcanic rock		697	763	66
fractured rock	X	763	765	
hard rock		765	775	

Bottom of hole is to be lined and screened after test pumping is completed 737 ft. to 775 ft.

Date started 5-8, 1983
Date completed 6-30, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 5/8 o.d. 6 5/8 o.d. 5 9/16 o.d. inches Total depth 775 feet
Casing record
Weight per foot Thickness 188 156

Diameter	From	To
8 5/8 o.d. inches	0 feet	304 feet
6 5/8 o.d. inches	255 feet	494 feet
inches	feet	feet
5 9/16 inches	428 feet	737 feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement grout
Depth of seal 264 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation NONE
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 4 Feet below land surface
Flow approx 125 G.P.M.
Water temperature Cool ° F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul Williams & Sons
Address 22 So. Patterson, Sparks
Nevada contractor's license number 14483
Nevada driller's license number 957
Signed Paul E. Williams
Date 7/8/83

USE ADDITIONAL SHEETS IF NECESSARY

O-627