

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF PATENT NO. 36778

1. OWNER Bennett Family Trust ADDRESS AT WELL LOCATION SIERRA WAY
 MAILING ADDRESS 6466 SIERRA WAY FALLON, NV 89406
 2. LOCATION NW 1/4 SE 1/4 Sec 18 T 19 N R 27 E Churchill County
 PERMIT NO. 08-113-38 Issued by Water Resources Parcel No. N. Robinson Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mad

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------|--------------|------|-----|------------|
| Fine Sand | ✓ | 0 | 35 | 35 |
| BR CLAY | | 35 | 47 | 7 |
| FINE SAND | | 47 | 87 | 40 |
| BARK CLAY | | 87 | 98 | 11 |
| COARSE SAND | ✓✓ | 98 | 110 | 12 |

8. WELL CONSTRUCTION
 Depth Drilled 110 Feet Depth Cased 110 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 110
10 5/8 Inches 0 Feet 110 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | | <u>5680PUC</u> | <u>+2</u> | <u>110</u> |

Perforations:
 Type perforation milled screen
 Size perforation D32
 From 100 feet to 110 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 110 feet

9. WATER LEVEL
 Static water level 19 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality Good

Date started 4-20 1999
 Date completed 4-21 1999

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|------------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>+30</u> | | <u>2 hrs</u> |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eddco Exploration Inc Contractor
 Address 7780 CURRY Rd. Contractor
FALLON, NV 89406
 Nevada contractor's license number 27673A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
 Signed William J. ...
 By driller performing actual drilling on site or contractor
 Date 4-22-99