WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75687
Permit No.
Basin 137B

NOTICE OF INTENT NO. 27468

1. OWNER Dan Brown
MAILING ADDRESS Round Mountain NV 89045
ADDRESS AT WELL LOCATION #1 R D Road Round Mountain NV 89045

2. LOCATION SW ¼ SE ¼ Sec. 4 T 10 N S R 43 E NYE County
PERMIT NO. (Issued by Water Resources) 021-461-56 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay (Brown)		0	10	10
Sands		10	43	33
Clay		43	45	2
Sands		45	50	5
Clays		50	59	9
Sands		59	70	11
Sticky clay Brown		70	73	3
Hard Clay		73	77	4
gravels w/Sands		77	78	1
Sands Coarse		78	88	10
Clay		88	92	4
Sands Coarse & Fine		92	107	15
Gravels Coarse Sand	X	107	108	1
Clay		108	110	2
Sands		110	112	2
Gravels	X	112	114	2
Hard clay		117	120	3
Fine Sands		120	128	8
Coarse Sand	X	128	134	6
Gravels	X	134	136	2
Coarse Sands		136	153	17
Sandy clay		153	156	3
Coarse Sands	X	156	170	14
sandy clay		170	173	3
Coarse Sands	X	173	180	7
Sandy Clay		180	187	7

Date started May 4, 1999
Date completed May 6, 1999

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailer	36	6	6
Pump	50	10	6

8. WELL CONSTRUCTION
Depth Drilled 187 Feet Depth Cased 187 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	+2 Feet	187 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188		

Perforations:
Type perforation mill slot
Size perforation 1/8" x 3"
From 111 feet to 131 feet
From 151 feet to 171 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 187 feet

9. WATER LEVEL
Static water level 9' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Inland Pacific Drilling Co Inc (Contractor)
Address 32 Almond Drive (Contractor)
Yerington NV 89447
Nevada contractor's license number issued by the State Contractor's Board 0036582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1958
Signed Doel W Brown (By driller performing actual drilling on site or contractor)
Date May 7 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627