

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40804

1. OWNER George Schiffilea ADDRESS AT WELL LOCATION Wade Lane Stagecoach, NV.
MAILING ADDRESS _____
2. LOCATION NW 1/4 SW 1/4 Sec. 10 T. 17 N/S R. 23 E Wyon County
PERMIT NO. 15-402-17 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other rod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sand</u>		<u>0</u>	<u>36</u>	
<u>Course Sand</u>		<u>36</u>	<u>53</u>	
<u>Gravels</u>		<u>53</u>	<u>91</u>	
<u>Tan clay</u>		<u>91</u>	<u>121</u>	
<u>Sand Gravel</u>		<u>121</u>	<u>147</u>	
<u>Gravels, Boulelers</u>		<u>147</u>	<u>170</u>	

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)
From 10 5/8 Inches To 170 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>3.00</u>	<u>5/16</u>	<u>16</u>	<u>170</u>
<u>6 5/16</u>	<u>13.00</u>	<u>3/16</u>	<u>11</u>	<u>10</u>

Perforations:
Type perforation Scill saw
Size perforation 1 1/2" x 6 Lines 7 Rows
From 150 feet to 170 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 0-50 Cement Grout
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From 50 feet to 170 feet

9. WATER LEVEL
Static water level 00' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 80.0 °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Beach Drilling Inc Contractor
Address Po Box 589 Silver Springs NV 89429 Contractor
Nevada contractor's license number 0031841 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources on-site driller 1007
Signed [Signature] By driller performing actual drilling on site or contractor
Date _____

Date started 4-15 1999
Date completed 4-17 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50 GPM</u>	<u>6 PM</u>	