WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75696
Permit No.
Basin 99

NOTICE OF INTENT NO. 22916

1. OWNER Cecil McLaughlin
MAILING ADDRESS P.O. Box 50028
Reno, NV 89513

ADDRESS AT WELL LOCATION 16400 Roundup
Reno, NV 89506

2. LOCATION SW ¼ SW ¼ Sec. 35 T 24 (N)/S R 18 E Washoe County
PERMIT NO. N/A (Issued by Water Resources) 078-272-01 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sandy clay		0	67	
Lt. Gray Sandy Clay		67	120	
Lt. Brown Sandy Clay		120	271	
Pink Rock		271	284	
Lt. Brown sandy clay		284	290	
Dark Brown Sy. Clay		290	293	
Lt Brown Sandy clay		293	355	
Gray Rock		355	380	

RECEIVED 99 MAY 25 AM 9:52 STATE ENGINEER'S OFFICE

Date started 12-7-98, 19
Date completed 3-6-99, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	100	370	4

8. WELL CONSTRUCTION
Depth Drilled 380 Feet Depth Cased 380 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 ¼	Inches	0	Feet	19	Feet
9 7/8	Inches	19	Feet	360	Feet
6 1/8	Inches	360	Feet	380	Feet
~~11~~		~~0~~		~~120~~	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	-1	360
5	11	.156	360	380

Perforations:
Type perforation Mill Slot
Size perforation 1/8 x 3"
From 320 feet to 360 feet
From 360 feet to 380 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50+
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 360 feet

9. WATER LEVEL
Static water level 25 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MILLER & SONS DRILLING CO. (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, Nv 89507

Nevada contractor's license number issued by the State Contractor's Board 037915

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418

Signed Bruce Miller
By driller performing actual drilling on site or contractor

Date 3-19-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627