WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75699
Permit No.
Basin 29

NOTICE OF INTENT NO. 41332

1. OWNER Paul Arney
MAILING ADDRESS HC 66 Box 21 Beowawe, NV. 89821

ADDRESS AT WELL LOCATION Cobble Lane, Crescent Valley

2. LOCATION NW 1/4 NW 1/4 Sec. 17 T 29 (N)S R 48 E Eureka County
PERMIT NO. | Issued by Water Resources | 03-011-05 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	
gravel		2	19	17
sand & gravel		19	43	24
sand		43	52	9
sand & gravel	x	52	70	18
sand & gravel w/clay	x	70	104	34

RECEIVED 99 JUN -8 AM 9:07 STATE ENGINEER'S OFFICE

Date started 5-21, 1999
Date completed 5-21, 1999

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		2

8. WELL CONSTRUCTION
Depth Drilled 104 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	50 Feet
9-7/8 Inches		50 Feet	104 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+2	100

Perforations:
Type perforation single row mill slot
Size perforation 1/8 x 3
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 104 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. Contractor
Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1154 T-1
Signed [signature] By driller performing actual drilling on-site or contractor
Date 6/5/99