

OFFICE USE ONLY
Log No. 85-1875-705
Permit No. 137B
Basin 137B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27940

1. OWNER BRUCE LARSON ADDRESS AT WELL LOCATION 1.5 MILES WEST OF HWY 376 TO LARSON BLVD THEN 2 MILES SOUTH - ON WEST SIDE LARSON BLVD. Round Mtn NW
MAILING ADDRESS P.O. Box 1920 ROUND MOUNTAIN NEVADA 89045
2. LOCATION NW 1/4 SW 1/4 Sec 4 T 10 N/S R 43 E. N/E County
PERMIT NO. 12-461-37 LARSON
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	4	4
BRN CLY		4	13	9
BIG GRAVEL		13	31	18
BRN CLY		31	38	7
SMALL GRAVEL		38	44	6
BRN CLY		44	47	3
SMALL GRAVEL & SAND		47	53	6
BRN CLY		53	58	5
BIG GRAVEL		58	63	9
BRN CLY		63	75	12
SMALL GRAVEL		75	83	8
BRN CLY		83	89	6
MED. GRAVEL		89	93	4
BRN CLY		93	125	32
MED. GRAVEL		125	132	7
BRN CLY		132	140	8
GRAVEL	X	140	159	19
BRN CLY		159	165	6

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 165 Feet
HOLE DIAMETER (BIT SIZE)
From To
10 5/8 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 165 Feet
Inches Feet Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
6 5/8 12.9 .188 72 165

Perforations:
Type perforation MILLED
Size perforation 3 X 18 DOUBLE ROW
From 145 feet to 165 feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Y ENVIRO 1146
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow NO G.P.M. _____ P.S.I. _____
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WOYTEK DRILLING CO INC Contractor
Address 2220 STOWE DRIVE Contractor
RENO NEVADA 89511
Nevada contractor's license number issued by the State Contractor's Board 024521A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Thomas M Harris
By driller performing actual drilling on site or contractor
Date 3-21-99

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>	<u>-</u>	<u>4 HRS</u>