

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 3/682

1. OWNER Steve Stevenson 1500 Hill Dr Gardnerville NV ADDRESS AT WELL LOCATION 1150 Quail Ln Carson City NV 89704
 MAILING ADDRESS Gardnerville NV

2. LOCATION NE 1/4 NE 1/4 Sec 27 T. 15 N S R. 20 E Carson County
 PERMIT NO. 10-083-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Blow sands		0	9	9
Hard Pan DE SANDS		9	63	54
Coarse DE sands		63	145	82
Fine clay beds DE SANDS		145	190	45
Coarse Volcanic Gravels and DE SANDS	XX	190	220	30

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>1.88</u>	<u>0</u>	<u>220</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 200 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 220 feet

9. WATER LEVEL
 Static water level 165 feet below land surface
 Artesian flow _____ G.P.M. 90-95 P.S.I.
 Water temperature 90 °F Quality Good

Date started 6-14 1999
 Date completed 6-16 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>25</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 KIK KAT DR Carson City NV 89704 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-15-99

RECEIVED
 1999 JUN 16 AM 10:52
 STATE WELL DRILLING OFFICE