

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19263

1. OWNER MARY CARLSON
 MAILING ADDRESS _____
 ADDRESS AT WELL LOCATION PAIUTE + JASPER SANDY VALLEY NV.
 2. LOCATION NW 1/4 NE 1/4 NW 1/4 Sec. 25 T. 24 N/S R. 56 E. CLARK County
 PERMIT NO. 200-25-101-013 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	6	6
CLAY		6	18	12
CALICHE		18	22	4
CLAY		22	44	22
CALICHE		44	50	6
CLAY		50	62	12
CALICHE		62	66	4
CLAY		66	76	10
CALICHE	W.B	76	80	4
CLAY		80	88	8
CALICHE	W.B	88	92	4
CLAY		92	110	18
CALICHE	W.B	110	115	5
CLAY		115	126	11
CALICHE	W.B	126	133	7
CLAY		133	140	7

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 140 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>4.33</u>	<u>.376</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation FACTORY SCREEN
 Size perforation 3 INCH BY 3 INCH
 From 130 feet to 100 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 6.6 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

Date started 6-8 1999
 Date completed 6-14 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BUDGET DRILLING CO Contractor
 Address P.O. Box 3505 Contractor
PAHRUMP NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 40020
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1523
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-14-99

RECEIVED
 99 JUL 16 AM 11:12
 STATE ENGINEERING OFFICE

