

OFFICE USE ONLY
 Log No. 75716
 Permit No. 49
 Basin
 NOTICE OF INTENT NO. 39327

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Bill Schrom ADDRESS AT WELL LOCATION Adobe Heights Subdivision
 MAILING ADDRESS SIERRA ESTATES EIKO NV
1450 STITZEL RD. ELKO NV 89801
 2. LOCATION SW 1/4 SW 1/4 Sec. 1 T. 34 S. R. 54 E. EIKO County
 PERMIT NO. 00551d037 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	20'	
BROWN CLAY		20'	220'	
GRAY & BROWN CLAY		220'	340'	
BLK & GRAY		340'	400'	
BROWN SILTS	520'	400'	540'	8'
GRAY CLAY		540'	620'	

8. WELL CONSTRUCTION
 Depth Drilled 620' Feet Depth Cased 540' Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 7/8 Inches To 0 Feet
 From 0 Feet To 620' Feet
 From 0 Feet To 0 Feet
 From 0 Feet To 0 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>1222</u>	<u>7/16</u>	<u>0</u>	<u>540</u>

Perforations:
 Type perforation Factory slots
 Size perforation 1/8
 From 420 feet to 520 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 620 feet

9. WATER LEVEL
 Static water level: 220' feet below land surface
 Artesian flow: 19 G.P.M. 180' P.S.I.
 Water temperature Cold °F Quality mucky

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AAA Drilling & Equipment Rental
 Address PO Box 2487 EIKO NV
 Nevada contractor's license number issued by the State Contractor's Board 0020684
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1670
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 5-16-99

Date started 5-13, 1999
 Date completed 5-17, 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>19</u>		<u>5</u>

RECEIVED
 99 JUN -2 PM 1:05
 STATE ENGINEERS OFFICE