WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35718
Permit No.
Basin 73A

NOTICE OF INTENT NO. 235

1. OWNER DWAYNE MCDUFFY
MAILING ADDRESS 11455 NEW EXCHECKER
LOVELOCK, NV 89419

ADDRESS AT WELL LOCATION 11455 NEW EXCHECKER

2. LOCATION NW 1/4 NW 1/4 Sec. 16 T 30 N/S R 33 E PERSHING County
PERMIT NO. Issued by Water Resources | Parcel No. | HUMBOLT RIVER ESTATES Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CEMENT 0-10'				
AQUA GUARD 10'-150'				
BR CLAY		0	3	3
MC COBBLES		3	30	27
MC CEMENTED GRAVELS		30	100	70
BLACK GRAVELS		100	185	85
MC CEMENTED GRAVELS		185	220	35
BROWN CLAY		220	230	10
MC GRAVELS	X	230	265	35

RECEIVED 99 JUL 15 AM 10:52 STATE ENGINEER'S OFFICE

Date started 6/28/1999 , 19__
Date completed 7/1/1999 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45+		1 HR

8. WELL CONSTRUCTION
Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/4	Inches	0	Feet	150	Feet
6 1/4	Inches	150	Feet	265	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	265

Perforations:
Type perforation MACHINE
Size perforation .080
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 150
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 135' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed By driller performing actual drilling on-site or contractor
Date 7/13/99

USE ADDITIONAL SHEETS IF NECESSARY