WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75722
Permit No.
Basin 89

NOTICE OF INTENT NO. 039842

1. OWNER Tom Fawcett
MAILING ADDRESS 606 Aredo De Carlos
Farmington, NM 87401

ADDRESS AT WELL LOCATION Will Sauer Rd., Lot 2

2. LOCATION SE 1/4 SE 1/4 Sec. 4 T 16N N/S R 19E E Washoe County
PERMIT NO. (Issued by Water Resources) 055-010-62 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand/granite cobbles		0	3	3
White weathered granite		3	118	115
Brown weathered granite	x	118	138	20
White weathered granite		138	178	40
Brown weathered granite	x	178	192	14
White weathered granite		192	200	8

RECEIVED 99 JUN 18 PM 12:09 STATE ENGINEER'S OFFICE

Date started 6/11/99, 19__
Date completed 6/14/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60+		2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	2+	200

Perforations:
Type perforation Mill Slot
Size perforation 3/32x3
From 120 feet to 140 feet
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100' feet to 200 feet

9. WATER LEVEL
Static water level 21 feet below land surface
Artesian flow no G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number, issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 6/15/99

USE ADDITIONAL SHEETS IF NECESSARY