WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75724
Permit No.
Basin 101

NOTICE OF INTENT NO. 41606

1. OWNER Tom Ingles
MAILING ADDRESS 2150 Mt. View Dr
Fallon, NV 89406

ADDRESS AT WELL LOCATION 5650 Allen Rd. Fallon Nv.

2. LOCATION NE 1/4 SE 1/4 Sec. 23 T 18N N/S R 28 E Churchill County
PERMIT NO. _____ Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	12	12
Brown Clay		12	17	5
Fine Brown Sand		17	26	9
Brown Clay		26	32	6
Gray Clay		32	37	5
Gray Sand		37	48	11
Green Sand		48	55	7
Black Clay		55	75	20
Black Sand		75	93	18
Green Clay		93	96	3
Brown Clay		96	134	38
Brown Sand	X	134	138	4
Green Clay		138	140	2

RECEIVED
99 JUN 10 AM 11:53
STATE ENGINEERS OFFICE

Date started 5/12/99, 19__
Date completed 5/12/99, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		1 hr

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6 pvc	3.96	.258	20	120

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 134 feet to 137 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 100 feet to 140 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling,Inc.
Contractor
Address P.O. Box 1264
Contractor
Fallon, Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 5/17/99

USE ADDITIONAL SHEETS IF NECESSARY