

OFFICE USE ONLY
 Log No. 75740
 Permit No. 49
 Basin. _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT 15539


1. OWNER Elizabeth Koepke ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4100 Paradise Drive # 37 Parcel # 37-062-05-6
EIKO NV 89801
 2. LOCATION SW 1/4 SW 1/4 Sec. 35 T 35 SR 55 E EIKO County _____
 PERMIT NO. N/A Issued by Water Resources Parcel No. _____ Subdivision Name Kittridge Canyon

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
caliche clay	-	0	20	20
cherty gravel	-	20	40	20
clay w/ gravel	-	40	60	20
gravel w/ minor clay	-	60	100	40
gravel-fine medium	-	100	120	20
coarse gravel w/ minor clay	-	120	180	60
fine gravel + sand	-	180	190	10
coarse gravel	-	190	230	40
coarse gravel	yes	230	260	30
coarse fine gravel minor sand	yes	260	300	40

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 295 Feet
 HOLE DIAMETER (BIT SIZE)
13 Inches From 0 Feet To 50 Feet
1 1/2 Inches From 50 Feet To 300 Feet
 _____ Inches From _____ Feet To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.7</u>	<u>.188</u>	<u>0</u>	<u>295'</u>

Perforations:
 Type perforation milled slot
 Size perforation 1/8"
 From 170 feet to 295 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 150 feet to 295 feet

9. WATER LEVEL
 Static water level 240 feet below land surface
 Artesian flow No G.P.M. N/A P.S.I.
 Water temperature 55 °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Gustin Corporation Contractor
 Address PO Box 894 Contractor
EIKO NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 0022193
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1821
 Signed Michael D. Zetter
 By driller performing actual drilling on site or contractor
 Date JUNE 12, 1999

Date started 6-7, 1999
 Date completed 6-10, 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>15-20</u>	<u>minimal</u>	<u>4 Hours</u>

RECEIVED
 99 JUN 17 AM 10:46
 STATE ENGINEERS OFFICE