

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 75742  
 Permit No. \_\_\_\_\_  
 Basin 103

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **39799**

1. OWNER **Bob Wunderlich** ADDRESS AT WELL LOCATION **#25 Daney Rd Dayton, NV 89403**  
 MAILING ADDRESS **PO Box 1003 Dayton, NV 89403**

2. LOCATION **NE 1/4 SE 1/4 Sec. 27 T 16 N/S R 21 E Lyon County**  
 PERMIT NO. **16-151-59** Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  
 Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **mud**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Black & orange volcanic rock		200	215	
Brown & green clay stone	X	215	220	5
Multi colored volcanic rock with gray & green clay	X	220	230	10
Gray & purple clay with orange volcanic rock		230	250	20
Gray & green volcanic rock		250	255	5
Gray & green clay with dark brown volcanic rock		255	270	15
Green & gray volcanic rock		270	280	10
Multi colored volcanic rock with gray clay		280	290	10
Multi colored volcanic rock		290	300	10
Gray & green volcanic and clay mixed		300	310	10
Gray & green volcanic rock with gray clay fractured		310	325	15

8. WELL CONSTRUCTION  
 Depth Drilled **325** Feet Depth Cased **230** Feet

HOLE DIAMETER (BIT SIZE)  
 From **7 7/8** Inches To **200** Feet  
 From **200** Feet To **325** Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>17.0</b>	<b>.225</b>	<b>90</b>	<b>230</b>

Perforations:  
 Type perforation **Factory sawed**  
 Size perforation **3/32X3**  
 From **230** feet to **190** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No  
 Depth of Seal **In place**  
 Placement Method:  Pumped  Poured  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level **30'** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **cold** °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **A.S.A.P. Pump & Well Service, Inc.** Contractor  
 Address **P.O. Box 60130** Contractor  
**Reno, NV 89506**  
 Nevada contractor's license number issued by the State Contractor's Board **35387-A**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2066**  
 Signed *[Signature]*  
 By driller performing actual drilling on-site or contractor  
 Date **5/20/99**

Date started **5/10/99**  
 Date completed **5/17/99**

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<b>8</b>		<b>3 hours</b>

RECEIVED  
 99 MAY 24 AM 11:18  
 STATE ENGINEERS OFFICE

*Deepening of log # 47234*