

OFFICE USE ONLY
 Log No. 75743
 Permit No. _____
 Basin 49

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42174

1. OWNER Dennis Stark ADDRESS AT WELL LOCATION Adobe Heights Subdivision
 MAILING ADDRESS SIERRA ESTATES Parcel 2 EIKO NV
1450 STITZEL RD. EIKO NV 89801
 2. LOCATION SW 1/4 Sec 1 T 34 R 54 E EIKO NV County _____
 PERMIT NO. S.W. SE 100551d 030 Parcel No. _____
 Issued by Water Resources _____ Subdivision Name 6207 MESA Dr.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown Alluvium</u>		<u>0'</u>	<u>60'</u>	
<u>Soft Brown</u>		<u>60'</u>	<u>220'</u>	
<u>Brown clays</u>		<u>270'</u>	<u>260'</u>	
<u>Black carbonaceous</u>		<u>260'</u>	<u>320'</u>	
<u>Red Oxides</u>		<u>320'</u>	<u>360'</u>	
<u>Soft brown</u>		<u>360'</u>	<u>420'</u>	
<u>Gray clays</u>	<u>420'</u>	<u>420'</u>	<u>600'</u>	<u>7</u>

8. WELL CONSTRUCTION
 Depth Drilled 600' Feet Depth Cased 560' Feet
 HOLE DIAMETER (BIT SIZE)
 From 14 3/4 Inches To 0 Feet 600' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>19</u>	<u>3/16</u>	<u>0</u>	<u>560'</u>

RECEIVED
 99 JUN -2 PM 1:05
 STATE ENGINEERS OFFICE

Perforations:
 Type perforation Factory Slots
 Size perforation 1/2
 From 300' feet to 560' feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50' Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50' feet to 600' feet

Date started 3-24, 1999
 Date completed 4-1, 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>1.5</u>		<u>6</u>

9. WATER LEVEL
 Static water level 280' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Silty

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AAA Drilling & Equipment Rental Contractor
 Address PO Box 2487 EIKO NV Contractor
89803
 Nevada contractor's license number issued by the State Contractor's Board 0020684
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1670
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4-5-99