WHITE–DIVISION OF WATER RESOURCES
CANARY–CLIENT'S COPY
PINK–WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75752
Permit No.
Basin 76

NOTICE OF INTENT NO. 40806

1. OWNER Khalar
MAILING ADDRESS
ADDRESS AT WELL LOCATION 11000 Donna Way, Yerington, NV.

2. LOCATION W ¼ SE ¼ Sec. 22 T 20 N/S R 25 E Lyon County
PERMIT NO. Issued by Water Resources
Parcel No. 21-472-08
Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Soil		0	6	
Sand Gravel		6	54	
Tan Clay		54	91	
Sand Gravel		91	133	
Brown Clay		133	157	
Gravel	✓	157	180	

RECEIVED 99 JUN 10 AM 11:53 STATE ENGINEER'S OFFICE

Date started 4-28, 19 99
Date completed 4-29, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
6 GPM	25	

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	0	180

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	18.00	3/16	+1	20
6"	3.00	Sch 40	20	180

Perforations:
Type perforation Scill Saw
Size perforation 1/4 x 2" Long 2 Rows
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-180
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 160 feet to 180 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Joseph Rollins Inc Contractor
Address P.O. Box 579 Contractor
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board C031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] By driller performing actual drilling on site or contractor
Date 4-29-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627