

OFFICE USE ONLY  
 Log No. 75754  
 Permit No. \_\_\_\_\_  
 Basin. 76

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40807

1. OWNER Bice ADDRESS AT WELL LOCATION 1975 Alpine  
 MAILING ADDRESS \_\_\_\_\_ Hemley, NV  
 2. LOCATION SE 1/4 1/4 Sec. 26 T 20 N/S R 25 E Nyon County  
 PERMIT NO. 21-491-49 Parcel No. 21-491-49 Subdivision Name South Highlands

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other well

6. LITHOLOGIC LOG

| Material         | Water Strata | From | To  | Thick-ness |
|------------------|--------------|------|-----|------------|
| Soil boulders    |              | 0    | 43  |            |
| Gravels          |              | 43   | 86  |            |
| Tan clay         |              | 86   | 94  |            |
| Cemented gravels |              | 98   | 196 |            |
| Red sand mud     |              | 146  | 235 |            |
| Loose gravels    |              |      |     |            |
| Cemented gravels |              | 235  | 385 |            |
| Coarse sand      |              | 386  | 400 |            |

8. WELL CONSTRUCTION  
 Depth Drilled 400 Feet Depth Cased 400 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 4 1/2 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>10 5/8</u>      | <u>13.00</u>        | <u>2 1/8</u>            | <u>0</u>    | <u>30</u>  |
| <u>6"</u>          | <u>3.00</u>         | <u>Sch 40</u>           | <u>30</u>   | <u>400</u> |

Perforations:  
 Type perforation Soil saw  
 Size perforation 1 1/2" / 1 3/4" / 2"  
 From 380 feet to 380 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0 - 00  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 0 feet to 400 feet

9. WATER LEVEL  
 Static water level 276 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Peak Drilling Inc Contractor  
 Address P.O. Box 379 Contractor  
Silver Springs NV 89409  
 Nevada contractor's license number 00318011  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1817  
 Division of Water Resources, the on-site driller  
 Signed Michael Peak  
 By driller performing actual drilling on site or contractor  
 Date 4-28-99

Date started 4-25 1999  
 Date completed 4-28 1999

7. WELL TEST DATA

| TEST METHOD:  | Ballor                        | Pump | Air Lift     |
|---------------|-------------------------------|------|--------------|
| <u>G.P.M.</u> |                               |      |              |
|               | Draw Down (Feet Below Static) |      | Time (Hours) |
| <u>6 P.M.</u> | <u>70</u>                     |      |              |

RECEIVED  
 19 JUN 10 AM 11:53  
 STATE ENGINEERS OFFICE

