

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37843

1. OWNER NYE COUNTY (CITY OF MANHATTAN) ADDRESS AT WELL LOCATION 150 TO 200 FEET
 MAILING ADDRESS TAMOPHY NEVADA 89049 SOUTHWEST OF WATER STORAGE TANK FOR
CITY OF MANHATTAN

2. LOCATION SW 1/4 NE 1/4 Sec. 20 T. 8 N/S R. 44 E. NYE County _____
 PERMIT NO. NONE FOUND Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
NO WELL LOG OR INFORMATION COULD BE OBTAIN ON THIS WELL - HOWEVER THIS WELL WAS DRILLED BY A CABLE TOOL RIG - BY LOOKS OF CASING & KIND IN THE SOFT. - WELL HOUSE WAS REMOVED FROM WELL - PUMP & MOTOR TANK WAS DROPPED DOWN WELL - COULD NOT BE FISHED OUT DUE TO HIGH POWER TENSION LINES BUILT OVER HEAD OF WELL. A ROLL OF 2" BLACK MOLY PIPE WAS UNTOILED INTO WELL DOWN TO 100 FEET. 70 SKS OF CEMENT WAS MIXED TO CEMENT THIS WELL FROM BOTTOM TO TOP. THE BLACK MOLY PIPE WAS THEN REMOVED FROM WELL. A TOP JOB OF CEMENTING WAS DONE ON THIS WELL AFTER 2 HRS TO BRING CEMENT TO GROUND LEVEL.				
70 SKS CEMENT - 6 LBS TO THE SACK WT. AT PUMPING 15.4 LBS.				

8. WELL CONSTRUCTION
 Depth Drilled 103 Feet Depth Cased 103 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 1/4 Inches 0 Feet 103 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>12.5</u>	<u>.134</u>	<u>UNKNOWN</u>	
<u>6 5/8</u>	<u>17.0</u>	<u>.250</u>	<u>72</u>	<u>103</u>

Perforations:
 Type perforation BEST GUESS MILLS KNIFE
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal UNKNOWN
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 42 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I. _____
 Water temperature COLD °F Quality FAIR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WOYTEK DRILLING CO. INC. Contractor
 Address 2220 S. TOWNE DR. Contractor
RENO NEVADA 89511
 Nevada contractor's license number issued by the State Contractor's Board 024521A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
 Signed Thomas M. Harris
 By driller performing actual drilling on site or contractor
 Date 5-20-99

Date started 5-19, 1999
 Date completed 5-19, 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED
 09 MAY 25 AM 9:51
 STATE ENGINEERS OFFICE