


STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 75768
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19393

1. OWNER FLEETWOOD HOMES ADDRESS AT WELL LOCATION 4330 VICTORIA ST
 MAILING ADDRESS 4330 VICTORIA ST
PAHRUMP, NV 89048

2. LOCATION SW 1/4 SE 1/4 Sec. 23 T 20S N/S R 52E E NYE County
 PERMIT NO. _____ Parcel No. 28-823-11 Subdivision Name CHARLESTON PARK RANCHOS

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	65	
CALICHIE	WB	65	80	15
CLAY		80	92	12
CALICHIE	WB	92	104	12
CLAY		104	110	6
CALICHIE	WB	110	119	9
CLAY		119	129	10
CALICHIE	WB	129	135	6
CLAY		135	140	5

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 10.25 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	3.63	.280	0	140

Perforations:
 Type perforation SAW CUT
 Size perforation 1/8 X 3

From <u>100</u> feet to <u>140</u> feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 84 feet below land surface
 Artesian flow _____ G.P.M.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas D...
 By driller performing actual drilling on-site or contractor
 Date 7/26/99

Date started 7/19/99, 19____
 Date completed 7/23/99, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

