

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. ~~7571~~ 75815
 Permit No. _____
 Basin 163

NOTICE OF INTENT NO. 19264

1. OWNER TOM PLUMERI
 MAILING ADDRESS _____
 ADDRESS AT WELL LOCATION PAYAGO + MARBLE SANDY VALLEY NV.
 2. LOCATION NW 1/4 SW 1/4 Sec. 25 T. 24 N. R. 56 E. CLARK County
 PERMIT NO. 580-230-081
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	2	2
CALICHE		2	4	2
CLAY		4	28	24
CALICHE		28	38	10
CLAY		38	56	18
CALICHE		56	61	5
CLAY		61	74	13
CALICHE	W.B	74	80	6
CLAY		80	91	11
CALICHE	W.B	91	103	12
CLAY		103	118	15
CALICHE	W.B	118	126	8
CLAY		126	134	8
CALICHE	W.B	134	138	4
CLAY		138	140	2

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation FACTORY SCREEN
 Size perforation 8 INCH BY 3 INCH
 From 120 feet to 100 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 FT. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140 feet to 50 feet

Date started 6-7 1999
 Date completed 6-8 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 65 FT. feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BUDGET DRILLING CO. Contractor
 Address P.O. BOX 3505 Contractor
PAHRUMP NV. 89041
 Nevada contractor's license number 40020
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1573
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-10-99

RECEIVED
 99 JUL 16 AM 11:12
 STATE ENGINEERS OFFICE

