MW-7

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75830
Permit No.
Basin 222

NOTICE OF INTENT NO. 17115

1. OWNER Peppermill Casinos, Inc.
MAILING ADDRESS 90 W. Grove Street, Suite 200
Reno, Nevada 89509 ATTN: Carole Hyde

ADDRESS AT WELL LOCATION
Oasis RV Park - 1134 W Mesquite Blvd
Mesquite NV 89024

2. LOCATION SE ¼ NE ¼ Sec. 18 T. 13 N/S R. 71 E. Clark County
PERMIT NO. MO-2362 Issued by Water Resources | 001-18-602-005 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. MW-7 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphaltic Concrete		0	5"	5"
Brown roadbase		5"	9"	4"
Brown to Yellow-Brown, moist, Very Loose to Loose poorly graded Sand w/ Silt (SP-SM) very fine to fine-grained.		9"	43'	42'
Water @ 37' bgs				

8. WELL CONSTRUCTION
Depth Drilled 43 Feet Depth Cased 43 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	43 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.125"			0	43

Perforations:
Type perforation Factory - Slotted
Size perforation 0.020"
From 27 feet to 42 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 25'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout ☑ Bentonite
Gravel Packed: ☑ Yes ☐ No
From 25 feet to 43 feet

9. WATER LEVEL
Static water level 37.0 feet below land surface
Artesian flow ND G.P.M. P.S.I.
Water temperature — °F Quality —

Date started 1 July, 1999
Date completed 1 July, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

N/C	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SPECTRUM EXPLORATION Contractor
Address 16662 GEMINI LANE Contractor
HUNTINGTON BEACH CA 92674
Nevada contractor's license number issued by the State Contractor's Board 34699
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2059
Signed [signature] By driller performing actual drilling on site or contractor
Date July 20-99

I

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627