

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **18767**

1. OWNER PALM HARBOR VILLAGE ADDRESS AT WELL LOCATION 5661 E. DOUBLETREE RD.
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SE 1/4 Sec. 16 T 21-S N/S R 54 E NYE County _____
 PERMIT NO. 43-091-09 COTTONWOODS @ HAFEN RANCH
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Sandy Loam		4	10	6
Brown clay/gravel		10	48	38
Cemented gravel		48	65	17
Brown clay/gravel	X	65	90	25
Brown clay		90	128	38
Brown clay/gravel	X	128	160	32

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 160 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet


CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	160

Perforations:
 Type perforation Torch Cut
 Size perforation 2" width 8" long
 From 120 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet



Date started JULY 1, 1999
 Date completed JULY 1, 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/2

9. WATER LEVEL
 Static water level 68 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name JIM PIKE WELL DRILLING, L.L.C. Contractor
 Address P. O. BOX 56 Contractor
PAHRUMP, NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 17563A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date JULY 13, 1999

