

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 75868
 Permit No. _____
 Basin 212

NOTICE OF INTENT NO. 16967

1. OWNER Brent Conrad ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4894 Lone Mountain Vacant
Rd. #187, LV, NV, 89130
 2. LOCATION NE 1/4 NW 1/4 Sec 23 T. 19S N/S R. 60 E. Clark County
 PERMIT NO. 125-23-702-004 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____


6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	30	
Caliche		30	35	
Clay		35	90	
Clay & Water	xx	90	140	
Clay		140	360	
Caliche & Water	xx	360	400	
Clay		400	520	
Limestone & Water	xx	520	565	

8. WELL CONSTRUCTION
 Depth Drilled ~~556~~ 565 Feet Depth Cased 565 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
 12 1/4 Inches 0 Feet 280 Feet
 10 5/8 Inches 280 Feet 565 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+1	565

Perforations:
 Type perforation Factory
 Size perforation 3/16 x 8 row
 From 525 feet to 545 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 200
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 200 feet to 565 feet



Date started 5/26/99, 19____
 Date completed 6/8/99, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 135 after cement job feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 5360 Bonita Vista Contractor
Las Vegas, Nev. 89149
 Nevada contractor's license number 10062 issued by the State Contractor's Board
 Nevada driller's license number issued by the 552 Division of Water Resources, the on-site driller
 Signed Vernon H. Dimick
 By driller performing actual drilling on site or contractor
 Date 6-17-99

