

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 75875  
 Permit No. 102  
 Basin 102

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18165

1. OWNER Rita LaMont ADDRESS AT WELL LOCATION 1710 W. Nye Road  
 MAILING ADDRESS 1710 W. Nye Road  
Pahrump, NV 89048

2. LOCATION NW 1/4 NW 1/4 Sec. 20 T 19S N/S R 53E E Nye County  
 PERMIT NO. 29-388-11 Crystallaire Estates  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>brown silty loam</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>See next line</u>		<u>8</u>	<u>14</u>	<u>6</u>
<u>brown loam stringes grey caleche</u>				
<u>grey caleche</u>		<u>14</u>	<u>25</u>	<u>11</u>
<u>See next line</u>	<u>x</u>	<u>25</u>	<u>52</u>	<u>27</u>
<u>brown loam grey caleche strings</u>				
<u>brown loam</u>	<u>x</u>	<u>52</u>	<u>62</u>	<u>10</u>
<u>brown calecke</u>	<u>x</u>	<u>62</u>	<u>87</u>	<u>25</u>
<u>See next line</u>	<u>x</u>	<u>87</u>	<u>124</u>	<u>37</u>
<u>brown loam grey caleche strings</u>				
<u>brown loam</u>	<u>x</u>	<u>124</u>	<u>140</u>	<u>16</u>

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140+1 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	Feet	To	Feet
<u>11</u>	<u>0</u>	<u>140</u>		

9. CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation sawcut  
 Size perforation .188

From	feet to	feet
<u>115</u>	<u>140</u>	

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 52 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

Date started 5/14/99 19  
 Date completed 5/14/99 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Bailer	Pump	
	Draw Down (Feet Below Static)		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor  
 Address 2301 Winery Road, Suite 2 Contractor  
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed [Signature]  
 By driller performing actual drilling on-site or contractor

Date 6-16-99

