


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **75877**
 Permit No. _____
 Basin **162**



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **18163**

1. OWNER **Lang & Scales** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **651 W. Jarvis** **651 W. Jarvis**
Pahrump, NV 89048

2. LOCATION **SE 1/4 NW 1/4 Sec. 28 T 19S N/S R 53E E Nye** County _____
 PERMIT NO. **29-901-12** Parcel No. **Bell Vista Estates** Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty loome		0	14	14
See next line		14	23	9
brown clay with caleche strings				
brown silty loome		23	34	11
See next line		34	38	4
brown silty loom with caleche				
See next line	x	38	50	12
brown loome with brown caleche				
brown loome	x	50	62	12
See next line	x	62	81	19
brown loome with brown caleche strings				
brown caleche	x	81	104	23
See next line	x	104	140	36
brown loome and brown caleche				

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140+1** Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	Feet	To	Feet
11	0	140		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation **sawcut**
 Size perforation **.188**

From **115** feet to **140** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal **50**

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From **50** feet to **140** feet

9. WATER LEVEL
 Static water level **52** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cool** °F Quality **good**

Date started **5/3/99**, 19____
 Date completed **5/3/99**, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Time (Hours)
	0					

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed _____
 By driller performing actual drilling on-site or contractor

Date **6.16.99**

