WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75896
Permit No.
Basin 162

NOTICE OF INTENT NO. 18145

1. OWNER Debbie & Trece Vacker
MAILING ADDRESS 5940 E. Doubtree
Pahrump, NC 89048

ADDRESS AT WELL LOCATION
5940 E.Doubletree

2. LOCATION SE 1/4 SE 1/4 Sec. 16 T 21S N/S R 54E E Nye County
PERMIT NO. ____ Issued by Water Resources | 43-071-16 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Loam		0	15	15
Brown Clay		15	32	17
Gray Calache		32	50	18
Brown Clay		50	60	10
Clay and Calache	x	60	75	15
Calache	x	75	100	25
Gravel and Clay	x	100	120	20
Calache	x	120	140	20

Date started 3/23/99, 19__
Date completed 3/23/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
0		

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140+1 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
Type perforation Sawcut
Size perforation .188
From 110 feet to 140 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed ____ (By driller performing actual drilling on-site or contractor)
Date 6-16-99

DOWNIDWR Received JUN 29 1999 LAS VEGAS OFFICE