

OFFICE USE ONLY
 Log No. **75898**
 Permit No. _____
 Basin **162**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **18142**

1. OWNER **Neal Napier & Robert Kruse** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **1791 W. Janet** **1791 W. Janet**
Pahrump, NV 89048

2. LOCATION **NW 1/4 SW 1/4 Sec. 32 T 19** N/S R **53E** E **Nye** County
 PERMIT NO. **29-782-18** Parcel No. _____ Subdivision Name **Rancho Del Sol**
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown clay		0	21	21
See next line		21	36	15
brown clay and calache strings				
brown clay w/loan strings		36	53	17
grey clay	x	53	106	53
grey clay w/calache strings	x	106	128	22
grey clay	x	128	140	12

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140+1** Feet

HOLE DIAMETER (BIT SIZE)
 From To
11 Inches **0** Feet **140** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet


CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation **Sawcut**
 Size perforation **.188**
 From **115** feet to **140** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **140** feet



Date started **4/8/99** _____ 19
 Date completed **4/8/99** _____ 19

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
 Static water level **58** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **Cool** °F Quality **Good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**
 Signed _____ By driller performing actual drilling on-site or contractor
 Date **6-16-99**

