

**WELL DRILLER'S REPORT**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **18524**

1. OWNER **Madison Marquette Retail Services**  
 MAILING ADDRESS **2800 28th Street, Suite 153**  
**Santa Monica, CA 90405**

ADDRESS AT WELL LOCATION **307 South Decatur**  
**Boulevard, Las Vegas, NV**

2. LOCATION **NE 1/4 SE 1/4 Sec. 36 T 20S**  
 PERMIT NO. **139-31-201-003**  
 Issued by Water Resources Parcel No.

N/S R **R60E E** Clark County  
 MW-10  
 Subdivision Name

3. WORK PERFORMED  
 New Well  
 Replace  
 Deepen  
 Abandon  
 Recondition  
 Other

4. PROPOSED USE  
 Domestic  
 Municipal/Industrial  
 Irrigation  
 Monitor  
 Test  
 Stock  
 Air  
 Cable  
 Rotary  
 RVC  
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Aphalt/Fill		0	0.5	.5
Silty sand		0.5	1	.5
Sand and gravel		1	4	3
Sandy clay		4	6	2
Sand		6	7	1
Clayey silt		7	12	5
Caliche		12	14	2
Silty Clay		14	25	11

8. WELL CONSTRUCTION

Depth Drilled **25** Feet Depth Cased **25** Feet

HOLE DIAMETER (BIT SIZE)

	From	To	From	To
Inches	6.5	0	25	25
Inches				
Inches				

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	25

Perforations:

Type perforation **Factory slot**  
 Size perforation **0.020**  
 From **15** feet to **25** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No  
 Depth of Seal **0-6 1/2' Bentonite**  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From **9** feet to **25** feet  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout

9. WATER LEVEL  
 Static water level **16** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

DRILLER'S CERTIFICATION

10. This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Don Wilison c/o Converse Consultants**  
 Contractor

Address **731 Pilot Road, Suite H**  
 Contractor

**Las Vegas, NV 89119**  
 Nevada contractor's license number  
 issued by the State Contractor's Board **48947**

Nevada driller's license number issued by the  
 Division of Water Resources, the on-site driller **M-1589**

Signed *Don Wilison*  
 By driller performing actual drilling on-site or contractor  
 Date **7/6/99**

Date started **6/24/1999**, 19  
 Date completed **6/24/1999**, 19

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift  
 Draw Down (Feet Below Static) Time (Hours)