

**WELL DRILLER'S REPORT**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18509

1. OWNER **Broadbent & Assoc. c/o Seven Crown Resorts**  
 MAILING ADDRESS **322 Lakeshore Road**  
**Boulder City, NV 89005**

ADDRESS AT WELL LOCATION **Echo Bay Resort, 64**  
**Northshore Road, Overton, NV 89040**

2. LOCATION SE 1/4 SE 1/4 Sec. 6 T 19S  
 PERMIT NO. 740-360-019 Parcel No.

N/S R R68E E Clark County

Issued by Water Resources

Subdivision Name W-5

3. WORK PERFORMED  
 New Well  
 Replace  
 Deepen  
 Abandon  
 Recondition  
 Other  
 Domestic  
 Municipal/Industrial  
 Irrigation  
 Monitor  
 Test  
 Stock  
 Cable  
 Air  
 Rotary  
 RVC  
 Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	0.5	5
Silty sand		0.5	19	18.5
Sandy gravel		19	30	11

8. WELL CONSTRUCTION

Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To	Feet	Feet
Inches	<u>12</u>	<u>0</u>	<u>30</u>	<u>30</u>
Inches				
Inches				

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>1.9</u>	<u>0.287</u>	<u>0</u>	<u>30</u>

Performations:

Type perforation **Factory slot**  
 Size perforation 0.020  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0.5/1.5-7' Bentonite  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 7 feet to 30 feet

9. WATER LEVEL

Static water level 21.13 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

DRILLER'S CERTIFICATION

10. This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Thomas High c/o Converse Consultants**

Contractor  
 Address **731 Pilot Road, Suite H**  
**Las Vegas, NV 89119**

Nevada contractor's license number  
 issued by the State Contractor's Board **48947**

Nevada driller's license number issued by the  
 Division of Water Resources **M-1869**

Signed \_\_\_\_\_  
 Date 6/28/99  
 By driller performing actual drilling on-site or contractor

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift  
 G.P.M.  Draw Down  Time (Hours)  
 (feet Below Static)

Date started 3/4/1999 \_\_\_\_\_ 19\_\_\_\_  
 Date completed 3/4/1999 \_\_\_\_\_ 19\_\_\_\_