WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75932
Permit No.
Basin 212

NOTICE OF INTENT NO. 18518

1. OWNER Pete Michelin
MAILING ADDRESS 9012 Night Owl Court
Las Vegas, NV 89134

ADDRESS AT WELL LOCATION 4130 Koval Lane, Las Vegas, NV

2. LOCATION NW 1/4 NE 1/4 Sec. 21 T T21S N/S R R61E E Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 162-21-503-003 Subdivision Name MW-1

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt/Fill		0	0.8	.8
Sandy Gravel		0.8	4.5	3.7
Sandy clay		4.5	6	1.5
Caliche		6	8.5	2.5
Clayey sand		8.5	10	1.5
Sandy clay		10	11.5	1.5
Gravel		11.5	12	.5
Sandy clay		12	14	2
Caliche		14	14.5	.5
Sandy clay		14.5	25	10.5

Date started 4/29/1999, 19__
Date completed 4/29/1999, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	25

Perforations:
Type perforation Factory slot
Size perforation 0.020
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0-6'/6-8' Bentonite
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 8 feet to 25 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thomas High c/o Converse Consultants (Contractor)
Address 731 Pilot Road, Suite H (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed (By driller performing actual drilling on-site or contractor)
Date 6/28/1999

USE ADDITIONAL SHEETS IF NECESSARY