

faxed: 6-1-99 8MD

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 75946
Permit No. _____
Basin 162

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18469

1. OWNER John Edwards-Tate ADDRESS AT WELL LOCATION 2490 Deacon Street
MAILING ADDRESS Pahrump, NV
2. LOCATION NE 1/4 NW 1/4 Sec. 36 T. 20 N. 53 E Nye County
PERMIT NO. 41-052-12 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>brown clay</u>		<u>0</u>	<u>12</u>	<u>12</u>
<u>light brown clay</u>		<u>12</u>	<u>24</u>	<u>12</u>
<u>Sandy Soil</u>		<u>24</u>	<u>48</u>	<u>24</u>
<u>Caliche</u>	<u>X</u>	<u>48</u>	<u>65</u>	<u>17</u>
<u>Sandy Soil</u>	<u>X</u>	<u>65</u>	<u>74</u>	<u>9</u>
<u>light brown clay</u>	<u>X</u>	<u>74</u>	<u>103</u>	<u>29</u>
<u>gray clay</u>	<u>X</u>	<u>103</u>	<u>124</u>	<u>21</u>
<u>Caliche</u>	<u>X</u>	<u>124</u>	<u>160</u>	<u>35</u>

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 160
12 Inches 0 Feet 160 Feet
CASING SCHEDULE
Size O.D. (Inches) 12 Weight/Ft. (Pounds) 17 Wall Thickness (Inches) .188 From (Feet) 0 To (Feet) 160

Perforations:
Type perforation Factory
Size perforation 4x12
From 120 feet to 160 feet
Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 50
Placement Method: Pumped Poured
Gravel Packed: Yes No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality GOOD

Date started 5-10-99, 19____
Date completed 5-12-99, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>5</u>	<u>1/2</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry Water Well Service Contractor
Address P.O. Box 3393 Contractor
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Larry Jenkins
By driller performing actual drilling on site or contractor
Date 6-1-99