

faxed 4-28-99 smd  
in Book

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 75949  
Permit No. \_\_\_\_\_  
Basin W2



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18465

1. OWNER Donny LaBlane ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS \_\_\_\_\_  
5330 N. Seans Street 5330 N. Seans St. Pahrump, NV 89041  
2. LOCATION SE 1/4 SW 1/4 Sec. 16 T. 19 N/S R. 53 E. Nye County \_\_\_\_\_  
PERMIT NO. 29-254-11 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy soil		0	7	7
brown clay		7	13	6
caliche		13	20	7
brown clay		20	25	5
caliche		25	27	2
brown clay	<input checked="" type="checkbox"/>	27	52	25
grey clay	<input checked="" type="checkbox"/>	52	65	13
brown clay	<input checked="" type="checkbox"/>	65	85	20
grey clay	<input checked="" type="checkbox"/>	85	105	25
brown clay	<input checked="" type="checkbox"/>	105	165	60
sandy clay	<input checked="" type="checkbox"/>	165	175	10
brown clay	<input checked="" type="checkbox"/>	175	200	25


8. WELL CONSTRUCTION  
Depth Drilled 200 Feet Depth Cased 200 Feet  
HOLE DIAMETER (BIT SIZE)  
From \_\_\_\_\_ To \_\_\_\_\_  
12 Inches 0 Feet 200 Feet  
\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	.188	0	200

Perforations:  
Type perforation Saw Cut  
Size perforation 1/2 x 4  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 165 feet to 190 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 50 feet to 200 feet



9. WATER LEVEL  
Static water level: 95 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality good

Date started 4-22-99, 19\_\_\_\_  
Date completed 4-24-99, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>0</u>	<u>1/2</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Larry's Water Well Service Contractor  
Address P.O. Box 3392 Contractor  
Pahrump, NV 89041  
Nevada contractor's license number 0035901  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1914  
Signed Larry Jenkins  
By driller performing actual drilling on site or contractor  
Date April 23, 1999