

Faxed 4-26-99 8MD

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 75950

Permit No.

Basin. 162

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18461

1. OWNER Ike Kuiuua ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Pahrump Nevada lot 12 Pioche st Pahrump, NV  
 2. LOCATION NE 1/4 NE 1/4 Sec. 2 T. 21S. N/S R. 53E E. Nye County  
 PERMIT NO. 44-162-02- Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG


Material	Water Strata	From	To	Thickness
brown clay		0	8	8
light brown clay		8	17	9
caliche		17	24	7
brown clay		24	43	19
sandy soil	X	43	68	25
brown clay	X	68	82	14
light brown clay	X	82	101	19
caliche	X	101	119	18
brown clay	X	119	138	39
light brown clay	X	138	140	2

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	.188	0	140

Perforations:  
 Type perforation factory  
 Size perforation 1/2" x 4"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet



9. WATER LEVEL  
 Static water level 52' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Pahrump Water Well Service Contractor  
 Address P.O. Box 3392 Contractor  
Pahrump, NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 0035901  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916  
 Signed Larry Jenkins  
 By driller performing actual drilling on site or contractor  
 Date April 23, 1999

Date started 2-18-99, 19\_\_\_\_  
 Date completed 2-20-99, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	30	0	1/2