WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 75954
Permit No.
Basin 162

NOTICE OF INTENT NO. 19046

1. OWNER Josh Moline
MAILING ADDRESS 1761 W. Greta Blvd
Pahrump, Nevada 89048

ADDRESS AT WELL LOCATION 1761 W. Greta Blvd.
Pahrump, NV.

2. LOCATION SW ¼ SW ¼ Sec. 32 T. 19 S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 29-729-15 (Parcel No.) Rancho Del Sol (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0'	5'	5'
brown clay		5'	15'	10'
caliche		15'	20'	5'
brown clay		20'	35'	15'
white clay		35'	50'	15'
caliche		50'	55'	5'
green clay		55'	65'	10'
white clay		65'	80'	15'
brown clay		80'	100'	20'
caliche		100'	105'	5'
brown clay		105'	120'	15'
caliche		120'	125'	5'
brown clay		125'	140'	15'

RECEIVED 99 JUN 14 AM 11:35 STATE ENGINEER'S OFFICE

Date started May 14, 1999
Date completed May 18, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0'	140'

Perforations:
Type perforation Saw Cut
Size perforation 1/8" x 3"
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140' feet

9. WATER LEVEL
Static water level 50' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lon Naillon Drilling (Contractor)
Address P.O. Box 265 (Contractor)
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 0035704
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest LaRue (By driller performing actual drilling on site or contractor)
Date May 19, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627