

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 76087  
Permit No. 63481  
Basin 205

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 6899

1. OWNER Burton Cox ADDRESS AT WELL LOCATION 950 Isaia Drive  
MAILING ADDRESS PO. Box 355 Masp9 NV Masp9 NV  
89025

2. LOCATION N/W 1/4 N/W 1/4 Sec. 27 T. 14 N. R. 66 E. Clark County  
PERMIT NO. 63481 Issued by Water Resources Parcel No. 690-150-010-93 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand - Boulders</u>		<u>0</u>	<u>38</u>	<u>38</u>
<u>Brown Clay - Boulders</u>		<u>38</u>	<u>140</u>	<u>102</u>
<u>White Clay - sand</u>	<u>X</u>	<u>140</u>	<u>179</u>	<u>39</u>
<u>gravel - Boulders</u>	<u>X</u>	<u>179</u>	<u>182</u>	<u>3</u>
<u>Hard Rock</u>		<u>182</u>	<u>185</u>	<u>3</u>

8. WELL CONSTRUCTION  
Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)  
From 16 Inches To 0 Feet 185 Feet  
Inches Feet Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>-</u>	<u>.188</u>	<u>0</u>	<u>185</u>

Perforations:  
Type perforation Factory  
Size perforation 1/8" x 3"  
From 125 feet to 185 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 100'  Neat Cement  
Placement Method:  Pumped  Concrete Grout  
 Poured  
Gravel Packed:  Yes  No  
From 100 feet to 185 feet

9. WATER LEVEL  
Static water level 41 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cool °F Quality fair

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Davis Drilling and Pumps Contractor  
Address P.O. Box 54 Hiko NV 89017 Contractor

Date started 5-25-99, 19\_\_\_\_\_  
Date completed 6-1-99, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>32</u>	<u>9</u>	<u>6</u>

Nevada contractor's license number issued by the State Contractor's Board 0028966  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191  
Signed Mark D. Davis  
By driller performing actual drilling on site or contractor  
Date 6-2-99

